CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7160-0972:101 Page 1 of 1

CATEGORY: Cables-Others

LISTEE: Atlas Wire & Cable, 133 S. Van Norman Rd., Montebello CA 90640

Contact: Tony Sanders *(323) 723-2401 FAX (562) 692-5176

DESIGN: Models CM, CMG, CMH, CMP, CMR, CMX, MP, MPG, MPP and MPR communication

cables.

Conductors: Two or more conductors.

Insulation: Solid SRPVC, North America Plastics, Grade "NORPLAS" 21570 and/or

Gitto/Global Corp, garde GA-8705-03P, Synergistics, Grade 1360-1021-PID.

Shield (Optional): Polyester film bonded to a aluminum foil; serving, wrap or braid of

aluminum wire or of metal-coated or uncoated copper wire (optional).

Jacket: PVC, North American Plastics, Grade "NORPLAS" 882A or Gitto/Global Corp., Grade

GA-8705-03, or Senergistics, Grade 1690-1060 PJD.

Refer to listee's data sheet for additional detailed product description and operational

considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances,

NEC Articles 725 and 800, and in a manner acceptable to the authority having jurisdiction.

Listee's name, Type "CM", "CMG", "CMH", "CMX", "CMP", "CMR", "MP", "MPG", "MPR", MARKING:

"MPP" and UL label.

APPROVAL: Listed as communication cables.

*Rev. 03-15-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 21, 2004 Date Issued: Listing Expires June 30, 2005

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager